



NOTES:

1. DIRECT BURY RATED WIRE ONLY
2. CONDUIT OPTIONAL
3. SEE ASSOCIATED DRAWING WPMS-I OR ASSOCIATED DRAWING SPMS-I

ITEM	TO BE SUPPLIED AND INSTALLED BY CONTRACTOR/HOMEOWNER:
A	APPLICABLE METER SOCKET
B	APPLICABLE AMP RATED CT CABINET
C	APPLICABLE AMP RATED OVER CURRENT DISCONNECT
D	GROUNDING IN ACCORDANCE WITH NEC REQUIREMENTS
E	SOURCE AND LOAD SIDE WIRE IN ACCORDANCE WITH NEC REQUIREMENTS



STANDARD FOR UNDERGROUND SERVICE
FROM OVERHEAD TRANSFORMER POLE
400AMP OR GREATER

FEBRUARY 2026

BY: JDG

REV: CEC

UGS-400-I